

**C009/ E2014**

**C2.5.2: Improvement of energy efficiency**

To improve energy efficiency while the ventilation system is working, an energy recovery system is installed inside AHU to recycle an estimated nominal 25% of energy input from heat coils inside the AHU.