

BUND WALL TEST CERTIFICATE

Test Certificate No. 19-609-02

Place: Delimara Power Station
Triq il-Power Station
Marsaxlokk, Malta.

Location: Delimara 4 – Gas Turbine G53 Lubricating Oil Tank

Description: Reinforced Concrete Bund Wall
Overall Dimensions: 10m x 1.75m x 0.92m
Capacity: Approx. 13.95m³ (Excluding side concrete Steps & Plinths)

Bund Lining Material: None

System Volume to be retained: Approx. 10000 litres

Methodology: Day 1: 3rd October 2019 at 09.30hrs
Bund cleaned of debris and any other liquids.
Bund filled with Water and level of water noted to be 195mm
Water allowed to settle for 24 hrs.

Day 2: 4th October 2019 at 09.30hrs
Level of Water in Bund Wall Noted to be 194mm

Result: Bund Wall Holds - Satisfactory

Other Remarks: Ambient Temperature: 28°C
Ventilation System Running



Water level at Start: 195mm



Water level after 24hrs: 194mm


Ing. Lawrence DimechDate: 4th October 2019