

**BUND WALL TEST CERTIFICATE**

Test Certificate No. 19-609-06

Place: Delimara Power Station  
Triq il-Power Station, Marsaxlokk, Malta.

Location: Delimara 4 – Hydrochloric Acid Dosing Skid Tank

Description: PTFE Tank – Thickness 1mm  
Overall Dimensions: 1250 x 1250 x 870mm  
Capacity: Approx. 1.36m<sup>3</sup>

Bund Lining Material: None

System Volume to be retained: Approx. 350 litres

Methodology: Day 1: 5<sup>th</sup> December 2019 at 09.35hrs  
Bund filled with Water and level of water noted to be 495mm  
Water allowed to settle for 24 hrs.

Day 2: 6<sup>th</sup> December 2019 at 09.35hrs  
Level of Water in Bund Wall Noted to be 495mm

Result: Bund Wall Holds - Satisfactory



Water level at Start: 495mm



Water level after 24hrs: 495mm

Ing. Lawrence Dimech

Date: 6<sup>th</sup> December 2019