

**BUND WALL TEST CERTIFICATE**

Test Certificate No. 18-606-03

Place: Delimara Power Station  
Triq il-Power Station  
Marsaxlokk,  
Malta.

Location: Compressors Area

Description: 0.1m Thick Reinforced Concrete Bund Walls – Quantity 3  
Overall Dimensions: 3.35m x 2.50m x 0.135m  
Volume Capacity: Approx. 1m<sup>3</sup>

Bund Lining Material: None

System Volume to be retained: Approx. 100 litres

Methodology: Day 1: 22<sup>nd</sup> August 2018 at 11.00hrs  
All 3 Bunds were cleaned of debris and any other liquids.  
Bunds filled with Water and level of water noted.  
No.1 – 43mm; No.2 – 45mm; No.3 – 42mm  
Water level marked and allowed to settle for 24 hrs.  
Day 2: 23<sup>rd</sup> August 2018 at 11.00hrs  
Level of Water in Bund Wall Noted:  
No.1 – 43mm; No.2 – 45mm; No.3 – 42mm

Result: Bund Wall Holds - Satisfactory

Other Remarks: Ambient Temperature: 34°C



Ing. Lawrence Dimech

Date: 26<sup>th</sup> August 2018