

**BUND WALL TEST CERTIFICATE**

Test Certificate No. 18-606-04

Place: Delimara Power Station  
Triq il-Power Station  
Marsaxlokk,  
Malta.

Location: Diesel Fire Fighting Pump

Description: 0.20m Thick Reinforced Concrete Bund Wall  
Overall Dimensions: 3.84m x 9.55m x 0.25m;  
Volume Capacity: Approx. 3.85m<sup>3</sup> (Excluding concrete Plinths)

Bund Lining Material: None

System Volume to be retained: Approx. 120 litres of Oil and Coolant

Methodology: Day 1: 22<sup>nd</sup> August 2018 at 12.00hrs  
Bund cleaned of debris and any other liquids. Bund filled with  
Water and level of water noted to be 32mm  
Water level marked and allowed to settle for 24 hrs.  
Day 2: 23<sup>rd</sup> August 2018 at 13.00hrs  
Level of Water in Bund Wall noted to be 31mm

Result: Bund Wall Holds - Satisfactory

Other Remarks: Ambient Temperature: 35°C

  
Ing. Lawrence DimechDate: 26<sup>th</sup> August 2018