

MICS

Marine and Industrial Consultancy Services Limited
'Nautic' 53, Triq L-Ortolan, San Gwann, SGN 1943, Malta.

Tel: +356 21384722 / 3

Fax: +356 21384724

Email: info@micsltd.org

BUND WALL TEST CERTIFICATE

Test Certificate No. 18-606-01

Place: Delimara Power Station
Triq il-Power Station
Marsaxlokk,
Malta.

Location: Jetty – Below LPG Manifold

Description: 0.2m Thick Reinforced Concrete Bund Wall
Overall Dimensions: 7.43m x 13.25m x 0.25m;
Volume Capacity: Approx. 21.92m³ (Excluding concrete Plinths)

Bund Lining Material: Coated with Hempadur 85671 (Curing Agent 97371)

System Volume to be retained: Approx. 2.18m³

Methodology: Day 1: 12th June 2018 at 12.00hrs
Bund cleaned of debris and any other liquids. Bund filled with Water and level of water noted to be 78mm
Water level marked and allowed to settle for 24 hrs.
Day 2: 13th June 2018 at 12.30 hrs
Level of Water in Bund Wall Noted to be 78mm

Result: Bund Wall Holds - Satisfactory

Other Remarks: Ambient Temperature: 33°C



Jetty Bund Wall



Initial Level of Water



Final Level of Water – After 24 hrs


Ing. Lawrence Dimech

Date: 26th August 2018