




EGM-HSE-EP-14

---

**Noise and Vibrations  
Management Plan**


|   |               |     |      |                                      |             |                           |
|---|---------------|-----|------|--------------------------------------|-------------|---------------------------|
|  | EGM-HSE-EP-14 |     |      | Noise and Vibrations Management Plan |             |                           |
|   | Version       | 1.0 | Date | 8 <sup>th</sup> July 2021            | Next Review | 8 <sup>th</sup> July 2022 |

## Document Information

|                         |   |  |
|-------------------------|---|--|
| <b>Version</b>          | Revision 1.1  |  |
| <b>Revisor</b>          | Christine Galea   | Regulatory & Compliance Officer                  |
| <b>Reviewers</b>        | Michael Sant  | Environmental Consultant                         |
|                         | John Chircop  | Technical Team Lead & Senior Electrical Engineer |
| <b>Approved by</b>      | <br>Jani Keraenen<br>CEO |  |
| <b>Date of approval</b> | 8 <sup>th</sup> July 2021   |  |

## Revision History

| Date                     | Version | Description                        | Sections amended | Revisor | Approver |
|--------------------------|---------|------------------------------------|------------------|---------|----------|
| 8 <sup>th</sup> Jul 2021 | 1.1     | General update;<br>Template update | all              | CG      | JK       |
|                          |         |                                    |                  |         |          |
|                          |         |                                    |                  |         |          |
|                          |         |                                    |                  |         |          |
|                          |         |                                    |                  |         |          |

|   |               |     |      |                                      |             |                           |
|---|---------------|-----|------|--------------------------------------|-------------|---------------------------|
|  | EGM-HSE-EP-14 |     |      | Noise and Vibrations Management Plan |             |                           |
|   | Version       | 1.0 | Date | 8 <sup>th</sup> July 2021            | Next Review | 8 <sup>th</sup> July 2022 |

## TABLE OF CONTENTS

|   |          |
|---|----------|
| <b>TABLE OF CONTENTS .....</b>                | <b>3</b> |
| <b>1. PURPOSE OF THIS DOCUMENT .....</b>      | <b>4</b> |
| <b>2. SCOPE .....</b>                         | <b>4</b> |
| <b>3. REFERENCES .....</b>                    | <b>4</b> |
| <b>4. DEFINITIONS .....</b>                   | <b>4</b> |
| <b>5. PROCEDURE.....</b>                      | <b>4</b> |
| 5.1 Introduction.....                         | 4        |
| 5.2 Noise Sensitive Locations/Receptors ..... | 5        |
| 5.3 Sources of Noise and Vibrations.....      | 5        |
| 5.4 Mitigation .....                          | 5        |
| 5.5 Near Field.....                           | 5        |
| 5.6 Far Field .....                           | 6        |
| 5.7 Office and Control Rooms.....             | 6        |
| 5.8 Conditions for sound guarantee .....      | 6        |
| 5.9 FSU Noise constraints .....               | 7        |
| 5.10 Noise Measurement Surveys.....           | 8        |
| 5.11 Remedial Actions .....                   | 8        |
| <b>6. RECORDS.....</b>                        | <b>8</b> |

|   |               |     |      |                                      |             |                           |
|---|---------------|-----|------|--------------------------------------|-------------|---------------------------|
|  | EGM-HSE-EP-14 |     |      | Noise and Vibrations Management Plan |             |                           |
|   | Version       | 1.0 | Date | 8 <sup>th</sup> July 2021            | Next Review | 8 <sup>th</sup> July 2022 |

## 1. PURPOSE OF THIS DOCUMENT

---

This procedure describes the noise and vibrations management plan for ElectroGas Malta Limited.

## 2. SCOPE

---

This procedure applies to all EGM operated areas within the Delimara Power Station Complex.

## 3. REFERENCES

---

|                 |   |
|-----------------|---|
| EGM-HSE-EMS     | Environmental Management System Manual                |
| EGM-HSE-PRO-001 | Public Grievance Mechanism                            |
| EGM-HSE-EP-01   | Corrective & Preventive Actions                       |
| EGM-HSE-EP-06   | Environmental Monitoring and Evaluation of Compliance |

## 4. DEFINITIONS

---

|             |  |
|-------------|--|
| EGM         | ElectroGas Malta Limited                 |
| HSE Manager | Health, Safety and Environmental Manager |
| NSP         | noise-sensitive positions                |

## 5. PROCEDURE

---

### 5.1 Introduction

The Noise Management Plan involves:

- consideration of sensitive receptors;
- consideration of noise sources;
- mitigation measures;
- monitoring of noise emissions; and
- remedial actions.

|   |               |     |      |                                      |             |                           |
|---|---------------|-----|------|--------------------------------------|-------------|---------------------------|
|  | EGM-HSE-EP-14 |     |      | Noise and Vibrations Management Plan |             |                           |
|   | Version       | 1.0 | Date | 8 <sup>th</sup> July 2021            | Next Review | 8 <sup>th</sup> July 2022 |

## 5.2 Noise Sensitive Locations/Receptors

**Sensitive receptors** are considered in the original EIA studies, where the situation remains unchanged; this document is to be read in conjunction with the study. Monitoring provisions are based on the study findings, and IPPC permit conditions.

The two nearest noise-sensitive positions (NSPs), PM1 & PM2, were identified during the EIS for the following reasons;

- Most exposed façades;
- Nearest and most exposed NSPs/receptors;
- There are at least five family groups that live in proximity to the area boundary (within 200 meters); and
- The measurement locations are also good to validate the noise model with regards to actual noise coming off the site i.e. to ensure that the various sound powers of the surfaces/items and propagation are within 3dB of each other signifying no major errors in the model.

## 5.3 Sources of Noise and Vibrations

The following is a list of assets that may be a source of noise and vibration from the EGM operated areas within the Delimara Power Station Complex.

- Gas turbines;
- Steam turbine;
- Generators;
- Cooling water pumps;
- FSU

## 5.4 Mitigation

EGM project was designed such that the noise generated through its operation under all operating conditions and site climatic conditions, complies with EU Directive 2002/49/EC and the Maltese Directive LN 193/2004 in order to comply with the limits imposed by the environmental and personnel safety regulations.

The gas turbine core engine has external insulation for personnel protection to both reduce the temperature on exposed surfaces, and to minimise external noise levels as well as noise levels within the enclosure. Heat and acoustic lagging are applied from compressor stage 3 at the cold end and continuously over the hot section and the exhaust diffuser to reduce temperature and noise.

The steam turbine and generators are also enclosed in metal acoustical enclosures designed for outdoor service.

## 5.5 Near Field

The surface sound pressure level was designed not to exceed 85 dB(A) during normal operation of the proposed development measured at 1m distance from any equipment or enclosure.

Measurements are undertaken in accordance to ISO 11204 "Acoustics- Noise emitted by machinery and equipment measurement of emission sound pressure levels at workstation and at other specified positions- Method requiring environmental correction".

|   |               |     |      |                                      |             |                           |
|---|---------------|-----|------|--------------------------------------|-------------|---------------------------|
|  | EGM-HSE-EP-14 |     |      | Noise and Vibrations Management Plan |             |                           |
|   | Version       | 1.0 | Date | 8 <sup>th</sup> July 2021            | Next Review | 8 <sup>th</sup> July 2022 |

Noise measurement points are evenly distributed, at 1m from the equipment and 1.5m above ground level (agl), from which a surface sound pressure level is calculated. This includes correction for baseline background noise and reflections and this corrected value will be compared with guaranteed sound pressure levels.

Both ambient background noise and noise at full load are measured.

If the difference between background noise and the Power Plant in operation at full load is between 6-15 dB(A), corrections will be undertaken in accordance with ISO 11204. If the difference is less than 6 dB(A), but the measured noise level at full load is less than the contract level, the sound guarantee will be considered as satisfactory. No measurements can be taken if the background noise is more than the contract level and the sound guarantee will be considered as satisfactory.

## 5.6 Far Field

The equivalent sound pressure level shall not exceed 65 dB(A) during normal operation measured at 100m distance from the proposed development site boundary. The measurement points will be placed in accordance with policy ANSI B 133.8 "Gas turbine installation sound emissions".

Both ambient background noise and the sound level for the operational power plant at full load will be measured. Typical measurement times for each point will be between 5-10 minutes and measurement points will not be located at sea level. Leq (A) measurement will be used. If the measurements are disturbed by non-stationary noise, like passing vehicles, L90 will be used. The L90 refers to when the sound pressure level is exceeded 90 percent of the time during the measurement period. The Lgo represent the steady-state sound pressure level at the measurement location. The wind speed will preferably be less than 6 m/s during the measurement and the weather conditions must be approximately the same during the measurement periods. Wind speed and direction, relative humidity and air temperature will be documented through the measurement period. If necessary, corrections for baseline background sound will be undertaken.

Measurements cannot be performed if the difference between the equipment at full load and background noise (ambient noise) is less than 3 dB. If this is the case, one of the following alternatives can be used for evaluating environmental noise:

1. Sound pressure measurements will be carried out closer to the Power Plant where the difference between the equipment at full load and background noise is greater than 3 dB(A). The procedure will follow ISO 8297.
2. Sound power levels will be measured for all dominating sound sources (except the stacks) belonging to the installation. The procedure will follow ISO 10494 - Gas turbines and gas turbine sets. Measurement of emitted airborne noise - Engineering/survey method will be used. The noise should then be predicted using ISO 9613-2 "Acoustics Attenuation of sound during propagation outdoors, Part 2: General method of calculation".


## 5.7 Office and Control Rooms

The sound pressure level contribution from equipment should not exceed 45 dB(A) in the main control room during normal operation measured in accordance with ISO 11204.

## 5.8 Conditions for sound guarantee

The sound guarantee is valid for Combined Cycle operation. The guarantee value is valid under the following conditions:

- Correction for background sound and reflections shall be made;

|   |               |     |      |                                      |             |                           |
|---|---------------|-----|------|--------------------------------------|-------------|---------------------------|
|  | EGM-HSE-EP-14 |     |      | Noise and Vibrations Management Plan |             |                           |
|   | Version       | 1.0 | Date | 8 <sup>th</sup> July 2021            | Next Review | 8 <sup>th</sup> July 2022 |

- The object under test is operated in continuous duty at full load, during normal operating conditions;
- All measurement readings will be made with slow response filter; and

Following operation modes are excluded from the sound guarantee:

- Blow down of the boiler;
- By-pass stack operation;
- By-pass operation of the steam turbine;
- Start-up and shut-down of the Power Plant;
- Operation below minimum load, i.e. 70% GT load;
- Safety valve blow;
- Construction and installation;
- Commissioning, including steam blow cleaning; and
- Other abnormal operation conditions:
- Blowing of rupture discs;
- Fast drainage of the feed water tank;
- Free blowing of steam from boiler to atmosphere;
- Power Plant trips.

## 5.9 FSU Noise constraints

The FSU has been built and maintained with NK Rules and in compliance with IMO Regulations. New equipment is certified to BV Rules and IMO regulations and maintained with BV Rules and to IMO regulations.

The specific standard for noise emissions is 2002/49/EC as well as all requirements of the EIA. Final noise survey was carried out once the FSU is operational to confirm that it meets the above criteria.

|   |               |     |      |                                      |             |                           |
|---|---------------|-----|------|--------------------------------------|-------------|---------------------------|
|  | EGM-HSE-EP-14 |     |      | Noise and Vibrations Management Plan |             |                           |
|   | Version       | 1.0 | Date | 8 <sup>th</sup> July 2021            | Next Review | 8 <sup>th</sup> July 2022 |

### 5.10 Noise Measurement Surveys

Ambient background noise level measurements were taken at various locations across the existing DPS as well as the NSPs above. Full details of the findings of this assessment are presented in the EIS. Noise monitoring regime in line with BS4142 will be set up as part of the operational procedures and will be included as part of the environmental management plan.

Noise monitoring that has taken place during the construction phase of the project shall be used as a basis of this monitoring. Combined noise monitoring will be carried out in conjunction with the other operators on the Delimara site. Enemalta will take the lead in this and have engaged with Acousti-CAL Consultancy to produce the noise monitoring method statement which is currently being discussed and reviewed by all parties.

Monitoring requirements are defined in the Environmental Monitoring and Evaluation of Compliance procedure, EGM-HSE-EP-06.

### 5.11 Remedial Actions

Abnormal noise emissions would either be noted by EGM staff or their designated sub-contractors, or through the Public Grievance Mechanism, EGM-HSE-PRO-001.

These will trigger action through the grievance procedures, as well as OTNOC procedure.

## 6. RECORDS

| Record Description       | Record Location/ Retention Responsibility | Minimum Retention Time |
|--------------------------|---|------------------------|
| Noise monitoring reports | Server folder '12. Certifications'        | Indefinite             |