

## Explanation to variation covered by the MPS Partial Surrender

A variation needs to be issued to the existing permit to cover the works described in the notification letter sent to MEPA dated 9<sup>th</sup> February 2015, mainly the dismantling and demolition of the following structures:

1. Chimney 1;
2. Chimney 3;
3. Tank 1;
4. Tank 2;
5. Tank 6; and
6. 2 Degassing Towers

Chimney 1 is connected to Boiler 3 and 4 which have not been in use since May 2012 as per letter sent to MEPA on 18<sup>th</sup> December 2014 and will no longer be used.

Chimney 3 was connected to the gas turbine in the A Station which was decommissioned in 1990.

All pipework from Tank 1, 2 and 6 will be decommissioned prior to the dismantling and demolition works to ensure that the tanks are isolated from any remaining plant.

The 2 degassing towers have been unused since 1989 and are disconnected from any other equipment.