

**Details of Combustion Plants at Sant' Antnin Waste Treatment Plant**

	Year of manufacture	Year of installation	Rated thermal input (at 100%)	Total operating hours	Average operating hours	Average load
Diesel Boiler	2002	2011	0.275 Mw	15768 Hours	2628 Hours	0.150Mw
Emergency Generator	2010	2011	0.72Mw	35.28 Hours	5.04 Hours	
CHP1 (Biogas)	2007	2011	1.2Mw	4980 Hours	2490 Hours (was only in operation for 2 years)	0.72Mw
CHP2 (Biogas)	2006	2011	0.7Mw	11095 Hours	1585 Hours	0.42Mw