

**Ing. Johan A. Psaila & Associates**  
**Consulting Engineers**

11, 'Redentur' Triq L-Isturnell Roza, Luqa LQA 3101  
Tel: 21 248 112 | Mob: 7980 1088 | e-mail: [johan\\_psaila@yahoo.co.uk](mailto:johan_psaila@yahoo.co.uk)

Our Ref. No. PP/JAP/R231-E/20

Date: 01<sup>st</sup> September 2020

*To whom it may concern*

**Location:** *Sant Antnin Waste Treatment Plant at Marsascala*  
**Report:** *Certification of Bund and its Roofing for Fuel Dispensing Installation*

---

Dear Sir/ Madame,

Reference is made to the subject in caption and further to our site-inspection that has been carried out on Thursday, 23<sup>rd</sup> July 2020 and below please find our record of examination for the bund and its roofing complimenting the liquid fuel storage tank used for dispensing fuel to vehicles.

**1.0 Scope of Report**

The scope of this report is to certify that the bund is leakproof and to certify the suitability of the associated roofing.

**2.0 Hydrostatic Testing of Bund**


The bund has been hydrostatically tested and confirm that it is leak-proof.

**3.0 Bund Roofing**

Further to our site inspection, it is hereby being confirmed that the roofing over the bund does not leak and is structurally sound and hence it can be concluded that it is suitable for its purpose.

**4.0 Conclusion**


The bund and its roofing shall be maintained throughout the operation of the liquid secondary storage facility and thus periodical inspection, checking and certification of such measures shall be carried out to ensure full functionality and compliance.



Ing. Johan A. Psaila  
Mechanical Engineer  
Warrant No: 858  
Tel: 2124 8112 • Mob: 7980 1088  
E-Mail: [johan\\_psaila@yahoo.co.uk](mailto:johan_psaila@yahoo.co.uk)

This certificate is valid for twelve (12 in no.) months and hence the bund and its roofing has to be re-certified prior to **23<sup>rd</sup> July 2021** and/or upon any additions, repairs and/or modifications to the same bund and/ or its roofing.

Yours Faithfully,



**Ing. Johan A. Psaila**  
B.Eng. (Hons.), Pg. Dipl. (Brunel)  
Warrant No. 858  
**Consulting Engineer**

## Annex A- Photos



**Fig. 01- General View of Bund and its Roofing**

Ing. Johan A. Psaila  
Mechanical Engineer  
Warrant No: 858  
Tel: 2124 8112 • Mgb: 7980 1088  
E-Mail: [johan\\_psaila@yahoo.co.uk](mailto:johan_psaila@yahoo.co.uk)