


Notes

- Extraction Grills with VCD's 600mm W x 400mm H each has a volume of 0.96m³/s - 2.5m from floor.
- 300 x 500 Egg Crate Extraction Grills with VCD's in vertical orientation - 2.5m from floor.
- Extraction Grills with VCD's 600mm W x 400mm H each has a volume of 1m³/s - 2.5m from floor.
- Location of ductwork droppers to plant/equipment shown indicative only. Exact locations of connection points to be determined on site upon installation.

1:80

0 1.6m 3.2m 8m

1.0	First Draft - For Approval	AR	AS	09/09/21
Rev	Note	Dwg	Chk	Date
This drawing and its contents are the property of CSO Group Ltd and must not be copied or disclosed to any third party without the written permission of CSO Group Ltd.				
<div><div><p><b>CSO Group</b> AD &amp; Pollution Solutions</p></div><div><p>Chequers Barn - Chequers Hill Bough Beech - Edenbridge Kent - TN8 7PD</p><p>T: +44 (0) 1732 700011 E: sales@csogroup.co.uk W: www.csogroup.co.uk</p></div></div>				
Title				
Wasteserv Malta Terminodour & Regenerative Thermal Oxidation Odour Control System				
Autoclave Building Extract Ductwork Layout - Plan View				
Drawn By	Date	Sheet	Scale	
AR	25/08/21	1/1	1:80 @ A1	
Drawing No.			Revision	
G002370-04-06			1.0	

