



- Notes
1. **Waste Marshalling Area** - Each dropper to be Ø150 with a balancing damper (VCD) before a 2m perforated diffuser and capped off. End of diffuser to be 1.5m above floor level.
 2. **Shredder Hall** - Each dropper to be Ø160 with a balancing damper (VCD) before a 2m perforated diffuser and capped off. End of diffuser to be 1.5m above floor level.

1.0	First Draft - For Approval	AR	AS	09/09/21
Rev	Note	Dwg	Chk	Date

This drawing and its contents are the property of CSO Group Ltd and must not be copied or disclosed to any third party without the written permission of CSO Group Ltd.



Chequers Barn - Chequers Hill
Bough Beech - Edenbridge
Kent - TN8 7PD
T: +44 (0) 1732 700011
E: sales@csogroup.co.uk
W: www.csogroup.co.uk

Title

Wasteserv Malta
Terminodour & Regenerative Thermal
Oxidation Odour Control System

Waste Marshalling Area & Shredder Hall
Ductwork Layout - Plan View

Drawn By	Date	Sheet	Scale
AR	18/08/2021	1/1	1:100 @ A2
Drawing No.			Revision
G002370-04-02			1.0

