

## 9 Removal

### 9.1 Procedure

Decommissioning is a very straight forward process, which has been detailed below:

1. The electrical supply to the control panel shall be isolated and locked off.
2. All cabling in and out of the control panel shall be disconnected, removed and disposed of accordingly
3. All ductwork shall be systematically removed from the building and either re-used or disposed of as appropriate.
4. The AHU shall be unbolted and craned out of position for disposal or re-use.