

## Scicluna Sylvana at Enemalta

---

**From:** vaccari, roberto (Barcelona) <roberto.vaccari@sgs.com>  
**Sent:** 02 May 2017 11:59  
**To:** Scicluna Sylvana at Enemalta  
**Cc:** Seguna, Aaron (Malta); silva santos, andrea (Barcelona)  
**Subject:** RE: Enquiry: Decommissioning of DPS 1 and review of safety reports (if any)

Dear Sylvana,

Happy to hear from you.

After checking the information submitted, I can state the following:

- **SR:** I see no need for a review of the Enemalta or Coordinated safety report prior to the decommissioning. We agreed to keep in the documents the presence of the HFO because the product may be used for other scope in the future. The decommissioning of the phase 1 is not going to change the presence of the HFO, except for phase 5, where some pumps considered in the risk analysis may be dismantled. After the decommissioning and when a decision has been taken on the HFO tanks and lines, I suggest to check and eventually review the document according to the future situation.
- **ERP:** I have to remind Enemalta that according to the Safety Management System Procedures, the ERP shall be updated periodically and in case of major change, thus I suggest Enemalta to keep updated the drawings, escapes routes and location and inventory of resources during the execution of each decommissioning phase.
- **Coordination / HAZID:** Whenever the works are going to impact on other activities, they have also to be communicated to the other stakeholders. In case of foreseeing possible hazards not included in the current version of the HAZID study, you may need to review it or to discuss potential impacts with the stakeholders (position of heavy tonnage cranes, falling of structures, falling of the chimney, truck movement, heavy structures blocking access roads, etc. )

Should you require any further assistance, do not hesitate to contact me.

Regards

**Roberto Vaccari**  
**Environment, Health & Safety**  
Process Safety Development Manager

**SGS Tecnos, S.A.**  
Mobile: +34 689 06 67 52  
E-mail: [roberto.vaccari@sgs.com](mailto:roberto.vaccari@sgs.com)

---

**De:** Seguna, Aaron (Malta)  
**Enviado el:** miércoles, 12 de abril de 2017 17:19  
**Para:** vaccari, roberto (Barcelona)  
**Asunto:** Enquiry: Decommissioning of DPS 1 and review of safety reports (if any)

Ciao Roberto, good afternoon.

As anticipated a few weeks ago Messrs Enemalta have finally come to us with regards to their below enquiry.

Shall await your feedback.

Thanks.

best regards

**Aaron Seguna**  
**Oil, Gas & Chemicals**  
Branch Manager

Mobile: +356 9915 2551  
Direct: +356 22 582 510  
Office: +356 21 650 600  
Fax: +356 21 650 650

---

**From:** Scicluna Sylvana at Enemalta [<mailto:sylvana.scicluna@enemalta.com.mt>]  
**Sent:** 12 April 2017 16:09  
**To:** Seguna, Aaron (Malta)  
**Subject:** Decommissioning of DPS 1 and review of safety reports (if any)

Dear Aaron,

As discussed some time ago, an IPPC requirement prior to the DPS 1 decommissioning is to determine whether there is the need of any changes to the safety studies conducted by Enemalta, or those conducted by the other operators. A summary of the plant/equipment to be decommissioned and dismantled is attached. Enemalta believes that since DPS 1 is not located close to the other operators' plants, and the HFO and Gasoil tanks will not be within the scope of this dismantling, it is not anticipated that the individual or coordinated safety studies will be affected. However, in view that SGS Italia conducted both the Enemalta and the coordinated safety studies, we would like SGS Italia to confirm this or otherwise.

You may wish to discuss with Mr. Roberto Vaccari and get back to us with way forward.

## **Decommissioning of DPS1**

2.16.17 Further to condition 2.2.2.9, the operator shall submit a decommiss for DPS 1 and any ancillary infrastructure as part of the application surrender of the application. This shall at least include all the inform in condition 2.16.9, and any changes required to the remaining plan both by Enemalta and the other operators as a result of this decomm

2.16.18 Such an application may require a review of:

- |           |   |
|-----------|---|
| 2.16.18.1 | the safety studies conducted by the operator  |
| 2.16.18.2 | the safety studies conducted by the other operators   |
| 2.16.18.3 | air dispersion modelling carried out for the installatio  |
| 2.16.18.4 | any other studies as may be deemed necessary by Competent Authority, the Authority and/or its Consultees. |

Thanks in advance.

Best regards,

**Sylvana Scicluna**

Manager Q.A., R.A.,EUA, H & S and Fire | Manager QA, RA, EUA, H&S & Fire Office | Enemalta plc

T: +356 22980583 | M: +356 79014880 | E: [sylvana.scicluna@enemalta.com.mt](mailto:sylvana.scicluna@enemalta.com.mt) | W: [www.enemalta.com.mt](http://www.enemalta.com.mt)



Think before you print! Consider the environment before printing this e-mail.

This email message (inclusive of any attachment/s thereto) may contain confidential and privileged information. It is intended only for the use of the stated addressee/s and access or reliance on this email message by any other person/s is unauthorised. You are hereby notified that if you are not the stated addressee/s you are strictly prohibited from reading, circulating, copying, distributing, disclosing, forwarding or using in any other manner any information contained in this email message or any attachment/s thereto. If you have received this email message (and/or any attachment/s thereto) in error and/or you are not the intended recipient/s thereof you are hereby kindly asked to destroy this email message (and any attachment/s thereto), as well as all copies thereof, and permanently delete this email message (and any attachment/s thereto) from your computer system/server and to notify us by return email, telephone on 80072224 or fax 22980261.

**Information in this email and any attachments is confidential and intended solely for the use of the individual(s) to whom it is addressed or otherwise directed. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of the Company. Finally, the recipient should check this email and any attachments for the presence of viruses. The Company accepts no liability for any damage caused by any virus transmitted by this email. All SGS services are rendered in accordance with the applicable SGS conditions of service available on request and accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>**