


30th April 2026

Subject: Feedback from WSC in view of EP00217/25 – AX Sunny Coast

To whom it may concern,

In relation to the review of EP00217/25, the Discharge Permitting Unit has no objection provided that the following conditions are respected:

1. All conditions present in the Public Sewer Discharge Permit (PSDP) with reference no. DMU 6068 shall be respected;
2. As per PSDP DMU 6068, the only trade effluent allowed to be discharged from this property is service water;
3. Any backwash water originating from pools containing water in excess of 1000 mg/L Chloride shall not be discharged into the public sewer network;
4. Reject waters from reverse osmosis plants shall not be discharged into the public sewer network;
5. Recirculation water forming part of the chilling system should not be discharged into the public sewer network;
6. Any chemicals stored on-site should be stored within a bunded area especially if the storage area has floor drains connected to the public sewer network;
7. Any changes to the operational conditions shall be reported to the Discharge Permitting Unit;



Lead Scientist – Discharge Permitting

Water Services Corporation
Triq Hal Qormi, Hal Luqa, LQA 9043, Malta

(+356) 2244 5566
customercare@wsc.com.mt

wsc.com.mt



ISO 14001 applies only to WSC Main Office,
Ta' Kandja P.S. and Pembroke R.O. Plant