

A.M. BROTHERS LIMITED
APT 1 VICMAG APT, TRIQ BERNARDETTE SAN GWANN MALTA
00356 99712223 mandplibya@gmail.com vat no. MT25233301

Date : 24th February 2023

To : [REDACTED]
Environmental & Resources Authority
Hexagon House Marsa, Malta

Re : AM Brothers Fire Report

To whom it may concern,

Further to the Site Visit carried out on the 16th February 2023 of the Fire Consultant and to your email dated 23rd of February 2023. The following are the detailed points of the Variation to be taken out by AM Brothers.

	Fire Consultant Report / Comments	AM Brothers Action Plan
1.	The Installation / positioning of the proposed structures as per the updated fire plan submitted on 25 th January 2023 bearing document number D 005/1/23 Rev 00.	Three (03) months after the Variation Approval
2.	The servicing of one fire extinguisher due to it being low on pressure.	One (01) month after the Variation Approval.
3.	The fire alarm be fitted with an auto-caller with the numbers programmed such that it would call first the owners/key holders' number and then the emergency service number (112).	Three (03) months after the Variation Approval

4.	Labelling of the wall socket (where the power supply for the alarm panel is connected to) with a sign similar to the sample given to ensure that this is not disconnected by accident.	One (01) month after the Variation Approval.
5.	Covering of the container with oil absorbing sand to minimise the absorption of moisture as a good operational practice to minimise the effort required when the sand needs to be used.	One (01) month after the Variation Approval

We hope that the above will consider for your favorable action.



Mohamed Moussa

Director

AM Brothers Ltd

