

Attachment 1: Stack emissions monitoring

Note: This relates to emissions from point sources, not ambient air monitoring.

Parameter monitored (e.g. NO _x , SO ₂ , dust)	Standard methodology used (EN or ISO standards preferred)	Emission point (e.g. scrubber, boiler)	Detection limit (include units)	Is this company accredited for this test?
O ₂	EN 50379-1 & EN 50379-2	Boiler, Generator	0 to 25% Res. 0.01%	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
CO	EN 50379-1 & EN 50379-2	Boiler, Generator	0 to 8000ppm Res. 1ppm	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
NO	EN 50379-1 & EN 50379-2	Boiler, Generator	0 to 5000ppm Res. 1ppm	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
Exhaust Temp.	EN 50379-1 & EN 50379-2	Boiler, Generator	-20°C to 250°C Res. 0.1°C	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
Exhaust Pressure	EN 50379-1 & EN 50379-2	Boiler, Generator	-200 mbar to 200 mbar Res. 0.01 mbar	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
Ambient Pressure	EN 50379-1 & EN 50379-2	Atmosphere	-200 mbar to 200 mbar Res. 0.01 mbar	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
Ambient Temp.	EN 50379-1 & EN 50379-2	Atmosphere	-20°C to 120°C Res. 0.1°C	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>